


- OUTSIDE EDGE SEALED WITH SPECIFIED SEALANT
- EXTERIOR CLOSURE FLANGE
- FASTENERS APPROX. 24" O.C.
- SEAL TOP OF FLASHING WITH A 3-COURSE OF SPECIFIED MASTIC AND REINFORCEMENT FABRIC FASTENED 8" O.C. TO WALL AND NAILER
- SCUPPER LINER WITH BUILT-IN CANT
- SCUPPER LINER SET IN FULL BED OF ASPHALT MASTIC AND PRIMED WITH ASPHALT PRIMER
- SPECIFIED BASE FLASHING BEYOND (SEE TYP. BASE FLASHING DETAIL(08-003K))
- GRAVEL GUARD
- SPECIFIED PLANTING
- SOIL
- 2-PLY MODIFIED BITUMEN MEMBRANE W/ WATER RETENTION SYSTEM, (FAMOGREEN RET CU-P4)
- FAMOBIT P4 BASE SHEET.
- SPECIFIED STRIPPING PLYES
- PROTECTION BOARD (FAMOFLORES INSULATION MATS)
- THERMAL INSULATION
- ROOF DECK

NOTES:

1. SUMP 2' AROUND SCUPPER OPENING TO PROMOTE WATER RUN OFF
2. SCUPPER LINER TO BE MANUFACTURED FROM 24 GAUGE GALVANIZED SHEET METAL AND ALL SURFACES THAT RECEIVE AN ADHERE MEMBRANE SHOULD BE PRIMED WITH ASPHALT PRIMER.
3. OUTSIDE EDGE OF SCUPPER SHOULD BE TOTALLY SEALED TO PREVENT WATER FROM ENTERING WALL CAVITY.
4. SCUPPER HEAD (NOT SHOWN) MUST BE BELOW OR HAVE SPILL-OUT BOTTOM LEVEL OF SCUPPER.
5. BREAK OUTSIDE TOP AND BOTTOM EDGES DOWN 45 DEGREES.
6. FLANGES SHALL BE A MINIMUM OF 6" WITH SOLID SOLDERED CORNERS.



THROUGH WALL SCUPPER DETAIL

SECTION

08-025K

NTS